

Edward Guy

105A-041
7

CERTIFICATION OF ELEVATION

DATE: 5/12/87

ADDRESS OF PROPERTY Lot 141

Harrietts Bluff

Camden County, Georgia

FLOOD ZONE A V OTHER A-12

Required lowest floor elevation 13.0 MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Actual lowest floor elevation 14.41 FT. MSL

The undersigned hereby certifies to the above information.

[Signature]
CAMDEN COUNTY
BUILDING INSPECTOR

STATE OF GEORGIA

REGISTRATION NO. 663 S.B.C.C.L.

REF. BM
TIDAL NO. 4 (OF GND)
(COPY ATTACHED)

10.81 FEET
3.60
14.41 FT. LOWEST F.F.L.