

118C-011

Cauch

CERTIFICATION OF ELEVATION

DATE: April 21, 1988

ADDRESS OF PROPERTY Lot 13, Block One,

Sadler Cove, Phase I

Camden County, Georgia

FLOOD ZONE A V OTHER _____

Required lowest finished floor elevation 13.00 MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Actual lowest floor elevation 13.80 MSL

The undersigned hereby certifies to the above information.

Park Dean Privett, Jr.
Privett & Associates, Inc.

STATE OF Georgia

REGISTRATION NO. 2218

FLOODPLAIN DEVELOPMENT/SPECIAL USE PERMIT

118C-011

Date: 2-16-88

Permit# 1991

FIRM # 130262 0405 B

Location of Property: Lt 13 Block 1 Saddle Creek

Applicant: Case Cont.

Address _____ Phone _____

Type of Development: _____ Excavation: _____ Fill: _____ Grading: Buildings

Other structures: _____ Other alterations (Specify): _____

Size of Development: _____

- Location in Floodplain: a. _____ In Velocity Zone
- b. A12 In Numbered A Zone
- c. _____ In Unnumbered A Zone

Development Standards Data (Ref: Ordinance# _____):

1. If a. above is checked, attach engineering certification and supporting data as required.
2. Required lowest floor elevation 13.0 MSL(NGVD).
3. Proposed lowest floor elevation _____ MSL(NGVD). Attach surveyed certification as required.
4. Flood-proofing information (if Applicable):
 - a. Required flood-proofed elevation _____ MSL(NGVD).
 - b. Actual (as built) flood-proofed elevation _____ MSL(NGVD). Attach engineering certification and supporting data as required.

Applicant acknowledgement: I understand that the issuance of this permit is contingent upon the above information being correct and that the plans and supporting data have been or shall be provided as required. I agree to comply with all applicable provisions of Ordinance# _____ and all other laws or ordinances affecting the proposed development.

Applicant (Signature) Patricia D. Adams Date 2/12/88

Has the correct fee been paid? () Yes () No Amount \$ 5.00

Date of Issuance _____ By _____

Department Use only:

- Inspection # _____ By _____
- Inspection # _____ By _____
- Inspection # _____ By _____
- Inspection # _____ By _____