

125A-046

DM

CERTIFICATION OF ELEVATION

DATE: July 29, 1988

ADDRESS OF PROPERTY Lot 101  
Hickory Bluff

FLOOD ZONE    A                     V     OTHER V-17

Required lowest floor elevation 14.00 MSL  
(If V Zone, required elevation of the bottom of  
the lowest horizontal structural member)

Actual lowest floor elevation 14.41 MSL

The undersigned hereby certifies to the above information.

Hugh D. Thomas  
HUGH D. THOMAS  
Registered Land Surveyor

STATE OF Georgia

REGISTRATION NO. 1395

*P-36*  
*Hickory Bluff*  
*3/5/88*

ate: 7-21-88

Permit# \_\_\_\_\_

FIRM # 130262-0155B

ocation of Property: LOT 101 Hickory Bluff

applicant: DOUGLAS ELECTRIC & PLUMBING

Address: Rt 5, Box 148 Douglas, GA (1) 384-2429  
31533 Phone

Type of Development: \_\_\_\_\_ Excavation: \_\_\_\_\_ Fill: \_\_\_\_\_ Grading:  Buildings

or other structures: \_\_\_\_\_ Other alterations (Specify): \_\_\_\_\_

Size of Development: \_\_\_\_\_

Location in Floodplain: a. V17 In Velocity Zone  
b. \_\_\_\_\_ In Numbered A Zone  
c. \_\_\_\_\_ In Unnumbered A Zone

Development Standards Data (Ref: Ordinance# \_\_\_\_\_):

1. If a. above is checked, attach engineering certification and supporting data as required.
2. Required lowest floor elevation 16.0 MSL(NGVD).
3. Proposed lowest floor elevation \_\_\_\_\_ MSL(NGVD). Attach surveyed certification as required.
4. Flood-proofing information (if Applicable):
  - a. Required flood-proofed elevation \_\_\_\_\_ MSL(NGVD)
  - b. Actual (as built) flood-proofed elevation \_\_\_\_\_ MSL(NGVD). Attach engineering certification and supporting data as required.

Applicant acknowledgement: I understand that the issuance of this permit is contingent upon the above information being correct and that the plans and supporting data have been or shall be provided as required. I agree to comply with all applicable provisions of Ordinance# \_\_\_\_\_ and all other laws or ordinances affecting the proposed development.

Applicant (Signature) [Signature] Date 7-21-88

Has the correct fee been paid? ( ) Yes ( ) No Amount \$ 5.00

Date of Issuance 7-21-88 By Tish Watson

Department Use only:

- Inspection # \_\_\_\_\_ By \_\_\_\_\_
- Inspection # \_\_\_\_\_ By \_\_\_\_\_
- Inspection # \_\_\_\_\_ By \_\_\_\_\_
- Inspection # \_\_\_\_\_ By \_\_\_\_\_

125A-046

CAMDEN COUNTY

ADMINISTRATIVE VARIANCE  
BASE FLOOD ELEVATION REQUIREMENT

NAME DOUGLAS ELECTRIC & PLUMBING  
 ADDRESS RT 5, Box 148 Douglas GA 31533 PHONE ( ) 384-2429  
 LOCATION OF PROPERTY LOT 101 Hickory Bluff  
 EXISTING FIRM# 130262 01550 (UL7-EL16)  
 REVISED FIRM# 1309C0130C (AE-14.0)  
 VARIANCE GRANTED 2.0'

In requesting this variance you are subjecting yourself to a higher flood insurance rate until the revised maps go into effect September 30, 1988.

[Signature]  
SIGNATURE

7-21-88  
DATE

Tish Watson  
ISSUED BY

7-21-88  
DATE

approved CCBC

8-2-88