

CERTIFICATION OF ELEVATION

132E-001

DATE: January 20, 1988

ADDRESS OF PROPERTY LOT 1

ELLIOTTS PLANTATION


29th GM DISTRICT

FLOOD ZONE      A  12      V       OTHER \_\_\_\_\_

Required lowest floor elevation 13.0 MSL  
(If V Zone, required elevation of the bottom of  
the lowest horizontal structural member)

Actual lowest floor elevation 14.68 MSL

The undersigned hereby certifies to the above information.



LEONARD E. HENRY, R.S.

P.O. Box 1246, Kingsland, GA 31548

STATE OF Georgia

REGISTRATION NO. 1842