

CERTIFICATION of ELEVATION

132E-010

June 10, 1988

NAME OF PROPERTY OWNER: RENCO Construction (Attn: Don Renshaw)
ADDRESS OF PROPERTY...: Lot 10, Elliotts Plantation
G.M.D.#.....: 29th

Flood Zone A12(EL13) (as scaled from FEMA Community Panel 130262
0405B dated 6-1-84).

Required lowest floor elevation 13.00 feet M.S.L.
Actual finished floor elevation 14.35 feet M.S.L.
Actual ground elevation 11.01 feet M.S.L.

The undersigned hereby certifies to the above information.



LEONARD E. HENRY, R.L.S.
Henry and Associates
Post Office Box 1246
Kingsland, GA 31548
State of Georgia,
Registration No. 1842

Reference Work Order #00878.