

CERTIFICATION OF ELEVATION

132E-026

DATE: March 16, 1987

ADDRESS OF PROPERTY Lot #26  
Elliotts Plantation  
29<sup>th</sup> G.m. District

FLOOD ZONE      A                       V       OTHER \_\_\_\_\_

Required lowest finished floor elevation 13.00 MSL  
(If V Zone, required elevation of the bottom of  
the lowest horizontal structural member)

Actual lowest floor elevation 13.97 MSL

The undersigned hereby certifies to the above information.

George E Henry

HENRY and ASSOCIATES  
SURVEYORS  
P. O. Box 1246  
Kingsland, GA. 31548

STATE OF Georgia

REGISTRATION NO. 1842