



BRANDON ASSOCIATES

SURVEYING — LAND PLANNING

308 ST. MARYS STREET
POST OFFICE BOX 1206
ST. MARYS, GEORGIA 31558
Telephone 912/673-6345

132 E-0666

CERTIFICATE OF ELEVATION

DATE: FEB. 22, 1991

ADDRESS OF PROPERTY: LOT 66 and a portion of LOT 65 Elliotts Plantation
1266 LANIER DRIVE
ST. MARYS, GEORGIA 31558

FLOOD ZONE AE (II) V OTHER

Required lowest floor elevation 11.00 MSL

(If V Zone, required elevation of the bottom of the lowest horizontal structural member)

Actual lowest floor elevation 11.41 MSL
GARAGE 11.02
A/C compressor pad 11.0 MSL

The undersigned hereby certifies to the above information.

Ben Brandon, Jr., R.L.S.

STATE OF GEORGIA

REGISTRATION # 2053