

CERTIFICATION OF ELEVATION

144A-019

DATE: March 29, 1988

ADDRESS OF PROPERTY Lot 19
GROVERVIEW Sub.
31st GM DISTRICT

FLOOD ZONE A 12 V OTHER _____

F.I.R.M. Community Panel #130262-0290B.

Required lowest floor elevation 13.00' MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Actual lowest floor elevation 17.35' MSL

The undersigned hereby certifies to the above information.


LEONARD E. HENRY, R.L.S.

P.O.Box 1246, Kingsland, GA 31548

STATE OF Georgia

REGISTRATION NO. 1842