

W08-07-002

CERTIFICATION OF ELEVATION

DATE: AUG. 29, 1987

ADDRESS OF PROPERTY SOUTHWEST CORNER OF  
6<sup>th</sup> STREET & COLE AVE,  
IN CITY LIMITS OF  
WOODBINE, GA

FLOOD ZONE A  V  OTHER \_\_\_\_\_

Required lowest floor elevation 14 MSL  
(If V Zone, required elevation of the bottom of  
the lowest horizontal structural member)

Actual lowest floor elevation 15.456 MSL

The undersigned hereby certifies to the above information.

Larry D. Williamson  
Reg Land Surveyor

STATE OF Georgia

REGISTRATION NO. 1397

P.E. 8773