

CERTIFICATION OF ELEVATION

153A 011

DATE: APRIL 18, 1987

ADDRESS OF PROPERTY LOT 10
DOVER'S BLUFF

FLOOD ZONE A V OTHER _____

Required lowest finished floor elevation 14.00 MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Actual lowest floor elevation 13.43 MSL

The undersigned hereby certifies to the above information.

Hugh O. Thomas

GEORGIA REGISTERED LAND SURVEYOR

STATE OF GEORGIA

REGISTRATION NO. 1395